## **Declaration of Conformity**

We ZHEJIANG YONGTAILONG ELECTRONIC CO., LTD. No.320 Tongsheng Road, Tongxiang Jiaxing, Zhejiang P.R. China, 314500

Ensure and Declare that the apparatus: **DEM4A00B** 

With the measurement range 3x230/400V 0,25-5(100)A 50Hz,1000imp/kWh,V301

are in conformity with the type as described in the EC-type examination certificate 0120/SGS0578

Annex II module "D", which assessment was established by the Notified Body SGS 0598

SN Number: 2024040001~ 2024040300 Batch Number: DE240227A

And satisfy the appropriate requirements of the Directive 2014/32/EU with the following standards:

EN 50470-1: 2006, Electricity metering equipment (AC) Part 1: General requirements, tests and test conditions. Metering equipment (class indexes A, B and C)

EN 50470-3: 2006, Electricity metering equipment (AC) Part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Place of Testing

YTL General Manager

**TongXiang** 

Date:5th,April,2024

Yao Yu